

Questions and answers submitted for Kiener Plaza Paver Repair

1. Q. The spec refers to grey poly sand joints....are they to be black in the surrounding splash pad area on the SW end to match existing?

A. That is correct: Black should be in the splash pad area, grey joint sand on the rest of the pavers to match.
2. Q. Do the granite 4x4 cobble pavers that are cracked in the splash pad area need to be replaced with the epoxy bed and epoxy joint material as installed?

A. Yes that is correct
3. Q. If concrete below the splash pad is found to be damaged will that result in additional removal and added scope?

A. Yes
4. Q. Do all of the joints in the entire plaza need to have the full 3" of joint sand removed or just cleaned enough for an over sweep of new polymeric sand?

A. Just cleaned enough to resweep new polymeric sand.